

OLYMPUS

7.9kVA PETROL GENERATOR Key Start With Electronic Ignition & AVR



JEFGENPET63EL

User Manual

CE




1. Contents

1. Contents	2
2. Parts Identification	2
3. Safety Information	3
4. Checking the Generator Prior to Use	4
5. Starting the Generator	4
6. Connecting Consumers to the Generator	5
7. Stopping the Generator	5
8. Transportation and Storage	5
9. Operation Environment	5
10. Maintenance	6
11. Troubleshooting	7
12. Parts List & Diagram	8
13. Circuit Diagram	10
Limited Warranty Statement	11
EC Declaration of Conformity	12

2. Parts Identification

- 1. Fuel cap
- 2. Key ignition
- 3. Power light
- 4. Circuit breaker
- 5. DC reset
- 6. AC Output
- 7. Earth connection
- 8. Battery
- 9. Voltage Meter
- 10. Wheel
- 11. Engine
- 12. Air filter
- 13. Fuel tank





3. Safety Information

- 1. The exhaust gas is poisonous, never use a generator indoors or in an attached garage. Always run your generator outdoors in a well-ventilated area. Keep the generator at least 1 meter (3 feet) away from buildings and other equipment during operation.
- 2. Place generator on level ground to operate.
- **3.** The load must be kept within rating stated on generator rating plate, overloading will damage the unit or shorten its life.
- 4. Running the engine at excessive speeds is dangerous and will damage the engine.
- 5. Do not tamper with parts, which may increase or decrease the governed speed.
- **6.** When using extension cords, please make sure they are grounded with sufficient wire gauge for the application. Heavy-duty outdoor rated cords will handle household appliance loads.
- **7.** The exhaust system gets hot enough to ignite some materials. Do not operate the engine near combustible materials.
- **8.** Do not store fuel indoors or try to refuel a generator while it is still running. Clean up any spilled fuel before restarting the engine.
- **9.** The muffler becomes very hot during operation and remains hot for a while after stopping the engine. Be careful not to touch the muffler while it is hot. Let the engine cool before storing the generator indoors.
- 10. Turn off all equipment powered by the generator before shutting down your generator.
- 11. To prevent electric shock or fire, never use the machine in rain or snow or connect the generator to a live circuit.
- **12.** Do not connect the generator to another power supply outlet.
- **13.** Protection against electrical shock depends on circuit breakers specifically matched to the generating set. If the circuit breakers require replacement they must be replaced with a circuit breaker having identical ratings and performance characteristics.
- **14.** Ensure the generator does not have any damaged hoses, loose or missing clamps, damaged tank or cap before use. All defects should be corrected before use.
- **15.** To prevent surging that may possibly damage equipment, do not allow the engine to run out of fuel when electrical loads are applied.
- 16. Before transporting the generator ensure that all the fuel is drained to prevent leakage.
- **17.** Unit must meet operating speed before electrical loads are connected. Always disconnect any loads before turning off the generator.
- **18.** Keep children and pets away from the generator at all times.
- **19.** The installation and major repair of the generator should only be carried out by trained and fully qualified engineers.
- **20.** Ensure appropriate ear protection is worn when working in close proximity to the generator.
- **21.** When using extension cables or mobile electric net use the following guidelines:

Cable Diameter	Maximum Length
1.5	60m
2.5	100m



WARNING:

- Do not cover the unit when in use.
- The unit should be earthed using 4mm diameter grounding wire.
- Do not use the generator in wet or damp conditions.
- Store the generator in well-ventilated area with an empty fuel tank.




4. Checking the Generator Prior to Use

- Check the fuel level and top up with unleaded petrol if necessary. Do not overfill the fuel tank (there should be no fuel in the filler neck).
- After refuelling make sure the tank cap is closed properly and securely. Be careful not to spill fuel when refuelling
 and clean up any spilled or excess fuel. Spilled fuel or fuel vapour can ignite when the engine
 is started.
- The generator has a maximum fuel capacity of 25 Litres
- Do not fill above the fuel filter top.
- Check the engine oil level and top up if necessary as shown in Fig.1.

5. Starting the Generator

Note: To make it easier to start the generator in cold temperatures remove the oil plug and add 2cc of engine oil before starting.

- **1.** Warm up the engine without the load for about 3 minutes.
- 2. Open the Fuel Cock.
- 3. Put the starting switch into the "Run" position.
- **4.** Hold the starting/recoil handle loosely and pull the cord out it until you feel resistance then return it slowly.
- **6.** Hold the starting/recoil handle firmly then pull the cord hard and fast as far as it will go. Use two hands if necessary. Repeat the process until the engine starts.





WARNING:

- Make sure there is no air in the fuel pipe when using the unit for the first time, starting the unit or refuelling an empty tank. You can drain away air by loosening the connection between the injection pump and pipeline then drain the air until the fuel comes out.
- Do not loosen or adjust either the engine speed limit bolt or fuel injection limit bolt. These have been set to their optimum settings before leaving the factory.
- Never pull out the start handle when diesel engine is running. This is dangerous and can damage the engine.



6. Connecting Consumers to the Generator

- **1.** Connect the machine you want to use to the AC socket. **Note:** Do not exceed the specified load limit of the specified maximum AC output.
- 2. Do not connect the generator to the household network as this may result in damage to the generator itself or to other electrical appliances in your home.

7. Stopping the Generator

- **1.** Before stopping the generator, allow it to run for approximately 3 minutes with no consumers so that it can "cool down".
- 2. Turn off the circuit breaker.
- 3. Turn the key/ignition switch to the "OFF" position.
- 4. Turn the fuel cock lever to the "CLOSED" position.

8. Transportation and Storage

- When transporting the generator, ensure the starting switch is set to the "OFF" position and that the fuel valve is set to the "Closed" position.
- Keep the generator level to prevent fuel spillage. Fuel vapour or spilled fuel may ignite. Touching a hot engine can cause serious burns or fires.
- Let the engine cool before transporting or storing the generator.
- Make sure not to drop or strike the generator when transporting. Do not place heavy objects on top of the generator during transit, storage or operation.

9. Operation Environment

• This unit can generate rated output under the following conditions:

Altitude	Ambient Temperature	Relative Humidty
0m	+20°	60%

• The Generator should work in low output under the following conditions:

Altitude	Ambient Temperature	Relative Humidty
>1000m	>40°	90%



9. Maintenance

The chart below indicates the maintenance checks you should make on your generator parts and the frequency that these checks should generally be carried out. **Note:** You can contact your nearest Jefferson dealer for help and advice and a full list of replacement parts.

Frequency Check	Daily	20 Hours Usage	50 Hours Usage	100 Hours Usage	300 Hours Usage
Engine oil check	0				
Replace engine oil		0		0	
Check air cleaner	0				
Wash the air cleaner			0		
Oil filter cup				0	
Oil filter				0	
Spark plug				0	
Valve clearance					0
Clean cylinder cover wash					
Fuel tank wash	Wash regularly replace every three years				
Check the battery and electrolyte levels	Before use				

Notes:

- Checking and the engine oil: With generator on level ground: remove the oil filler cap and dipstick clean with a clean cloth. Insert the dipstick back into the oil filter hole without turning remove and check that the oil level is between the minimum and maximum indicators. If level is low refill to the maximum level mark.
- Checking the fuel level: With generator on level ground: open the fuel tank cap. Check the fuel level. If level is low refuel up to the red marker on the fuel filter. Put the fuel cap back on.



WARNING:

- Ensure that any electrical equipment is disconnected from the generator before carrying out any maintenance work on the generator.
- The circuit breaker should be in the "OFF" position before maintenance.
- The unit should be eatherd at all times.



10. Troubleshooting

Symptom Possible Cause		Action	
	Not enough fuel oil	Add fuel - see section "4. Checking Generator Prior to Use"	
Funcius waste stant	Fuel nozzle cannot inject fuel or there is not enough fuel	Repair the fuel injector	
Engine won't start	The speed control lever is not in the "Run" position	Move the lever to the "Run" position	
	Lubricant oil level is too low	Check that the oil level is topped up and sits between the upper and lower level markers	
	Not enough speed or force used on the starter/recoil handle	See section "5. Starting the Generator"	
	The fuel nozzle is blocked or dirty	Clean tthe fuel nozzle	
	Circuit breaker is not closed	Turn the circuit breaker to the "On" position	
	Poor or faulty socket connection	Adjust the socket feet	
Generator fault	The rated generator speed cannot be obtained	Adjust to rated speed	
donorator laart	Carbon brush is faulty or worn	Replace the carbon brush	
	AVR is depreciated	Replace the AVR	

11. Technical Specification

FREQUENCY:	50Hz
RATED OUTPUT:	7.2kVA / 5.8kW
MAX OUTPUT:	7.9kVA / 6.3kW
POWER FACTOR:	0.8
AC OUTPUT:	1 X 230V 32A / 1 X 110V 32A
DC OUTPUT:	12V / 8.3A
ENGINE MODEL:	MACGEN 14.0HP / 3600RPM
ENGINE TYPE:	OHV PETROL • AIR-COOLED • 4 STROKE
STARTING SYSTEM:	KEY / RECOIL START WITH ELECTRONIC IGNITION & AVR
GUARANTEED NOISE LEVEL:	97 dB Lwa
FUEL TANK:	25L
RUNNING TIME:	10 HOURS
DISPLACEMENT CAPACITY:	422cc
LUBRICATION OIL VOLUME:	1.1L
LOW OIL SHUTDOWN:	YES

Noise Level Information

The figures quoted in this table are emission (sound power) levels and are not necessarily safe working levels.

Whilst there is a correlation between the emission and exposure levels, this can not be used reliably to determine whether or not further precautions are required.

Factors that influence the actual level of exposure to the work-force include the characteristics of the work room, the other sources of noise, the number of machines and other adjacent processes, and the length of time for which an operator is exposed to the noise. Also the permissible exposure level can vary between regions.

This information, however, will allow the user of the machine to make a better evaluation of the hazard and risk.




12. Parts List and Parts Diagram

#	Code	Description	Qty	#	Code	Description	Qty
1	012080000043	Up190e engine	1	29	029050400100	Wheel	2
2	02999000701	Crankcase windshield cover	1	30	512071200000	Blocking nut m12	2
3	062023420005	Rotor	1	31	022560500082	Frame	1
4	062023430002	Stator	1	32	029027100008	Control panel	1
5	029030102501	Alternator guard board	1	33	029050400301	Underlay	2
6	029030430700	190 Rear end cover	1	34	029050400401	Underlay bracket	1
7	029030500101	Wire fasten connection	1	35	029930000801	Grounding wire	1
8	029910300301	Shock absorption	4	36	029050601383	Left handle bracket	1
9	029030620201	5Kw avr	1	37	029050600101	Pressure button spring	2
10	029030300314	190 Rear end cover	1	38	029050601583	Handle	2
11	029030700200	Carbon brush	1	39	029050601483	Right handle bracket	1
12	029840200200	Mufler gasket	1	40	029050400602	Handle cover	2
13	029840101101	Muffler	1	41	511050804505	Flange bolt m8x45	2
14	029049910600	Mufler bracket	1	42	512120800005	Acorn nut m8	6
15	029010500102	Fuel tank	1	43	511160804505	Button head square neck bolt m8*45	4
16	029019900602	Fuel tank filter	1	44	029840400400	Muffler protect side guard	1
17	029019901102	Fuel tank cap	1	45	029840340000	Muffler protect outside guard	1
18	029019930000	Fuel marker assembly	1	46	513010800001	Flat washer Ø8	2
19	029019910001	Shock absorption	4	47	513020800002	Spring washer Ø8	2
20	029019900408	Ø7 clamp	1	48	513041000006	Large flat washer Ø10(h=3)	1
21	029019900100	Ø4.5Mm fuel pipe	1	49	513021000002	Spring washer Ø10	1
22	029019900401	Ø8 clamp	1	50	511011026501	Rotor bolt m10x265	1
23	02901990070904	Fuel switch	1	51	513020600002	Spring washer Ø6	5
24	029960900201	Battery platen	1	52	511050617501	Flange bolt m6x175	4
25	029960200100	Battery	1	53	513030500000	External tooth lock washer Ø5	2
26	029969900219	Battery wire(black)	1	54	513010500001	Flat washer Ø5	10
27	029969900220	Battery wire(red)	1	55	513020500000	Spring washer Ø5	6
28	029050412000	Axle	2			l .	


,	#	Code	Description	Qty
	56	511050501601	Flange Bolt M5x16	7
	57	511140502000	Full-Thread Bolt M5x20	4
	58	512010500001	Nut M5	8
	59	511050501201	Flange Bolt M5x12	5
	60	512040800001	Flange Nut M8	13
	61	512041000000	Flange Nut M10	6
	62	513040800000	Large Flat Washer Ø8	1
	63	511050804001	Flange Bolt M8x40	1
	64	511050601201	Flange Bolt M6x12	8
	65	510050802501	Flange Bolt M8x25(With Flat Washer)	4
	66	517050401204	Fillister Head Bolt M6x12	4
	67	512040600001	Flange Nut M6	5
	68	511050801601	Flange Bolt M8x16	2
	69	511050601401	Flange Bolt M6x14	3
	70	513010600001	Flat Washer Ø6	1
	71	513030600000	External Tooth Lock Washer Ø6	1
	71	029911300102	Shock Absorption	1







13. Circuit Diagram





Limited Warranty Statement

Jefferson Professional Tools & Equipment, or hereafter "Jefferson" warrants its customers that its products will be free of defects in workmanship or material. Jefferson shall, upon suitable notification, correct any defects, by repair or replacement, of any parts or components of this product that are determined by Jefferson to be faulty or defective.

This warranty is void if the equipment has been subjected to improper installation, storage, alteration, abnormal operations, improper care, unauthorised service or repair.

Warranty Period

Jefferson will assume both the parts and labour expense of correcting defects during the stated warranty periods below.

All warranty periods start from the date of purchase from an authorised Jefferson dealer. If proof of purchase is unavailable from the end user, then the date of purchase will be deemed to be 3 months after the initial sale to the distributor.

1 Year

All Jefferson petrol and diesel generators

90 Days

· All replacement parts purchased outside of the warranty period

Important: All parts used in the repair or replacement of warranty covered equipment will be subject to a minimum of 90 days cover or the remaining duration of the warranty period from the original date of purchase.

Warranty Registration / Activation

You can register and activate your warranty by visiting the Jefferson Tools website using the following address: www.jeffersontools.com/warranty and completing the online form. Online warranty registration is recommended as it eliminates the need to provide proof of purchase should a warranty claim be necessary.

Warranty Repair

Should Jefferson confirm the existence of any defect covered by this warranty the defect will be corrected by repair or replacement at an authorized Jefferson dealer or repair centre.

Packaging & Freight Costs

The customer is responsible for the packaging of the equipment and making it ready for collection. Jefferson will arrange collection and transportation of any equipment returned under warranty. Upon inspection of the equipment, if no defect can be found or the equipment is not covered under the terms of the Jefferson warranty, the customer will be liable for any labour and return transportation costs incurred.

These costs will be agreed with the customer before the machine is returned.

* Jefferson reserve the right to void any warranty for damages identified as being caused through misuse



Warranty Limitations

Jefferson will not accept responsibility or liability for repairs made by unauthorised technicians or engineers. Jefferson's liability under this warranty will not exceed the cost of correcting the defect of the Jefferson products.

Jefferson will not be liable for incidental or consequential damages (such as loss of business or hire of substitute equipment etc.) caused by the defect or the time involved to correct the defect. This written warranty is the only express warranty provided by Jefferson with respect to its products.

Any warranties of merchantability are limited to the duration of this limited warranty for the equipment involved.

Jefferson is not responsible for cable wear due to flexing and abrasion. The end user is responsible for routine inspection of cables for possible wear and to correct any issues prior to cable failure.

Claiming Warranty Coverage

The end user must contact Jefferson Professional Tools & Equipment (Tel: +44 (0) 1244 646 048) or their nearest authorised Jefferson dealer where final determination of the warranty coverage can be ascertained.

Step 1 - Reporting the Defect

Online Method:

• Visit our website www.jeffersontools.com/warranty and complete the Warranty Returns form. You can complete the form online and submit it to us directly or download the form to print out and return by post.

Telephone Method:

Contact your Jefferson dealer or sales representative with the following information:

- Model number
- Serial number (usually located on the specification plate)
- Date of purchase

A Warranty Returns form will be sent to you for completion and return by post or fax, together with details of your nearest authorised Jefferson repair centre. On receipt of this form Jefferson will arrange to collect the equipment from you at the earliest convenience.

Step 2 - Returning the Equipment

It is the customer's responsibility to ensure that the equipment is appropriately and securely packaged for collection, **together with a copy of the original proof of purchase**. Please note that Jefferson cannot assume any responsibility for any damage incurred to equipment during transit. Any claims against a third party courier will be dealt with under the terms & conditions of their road haulage association directives.

Please note: Jefferson will be unable to collect or process any warranty requests without a copy of the original proof of purchase.

Step 3 - Assessment and Repair

On receipt, the equipment will be assessed by an authorised Jefferson engineer and it will be determined if the equipment is defective and in need of repair and any repairs needed are covered by the warranty policy. In order to qualify for warranty cover all equipment presented must have been used, serviced and maintained as instructed in the user manual.



Where repair is not covered by the warranty a quotation for repair, labour costs and return delivery will be sent to the customer (normally within 7 working days).

Note: If the repair quotation is not accepted Jefferson Professional Tools & Equipment will invoice 1 hour labour time at £30 per hour plus return carriage costs (plus VAT).

In cases where no fault can be found with the equipment, or, if incorrect operation of the equipment is identified as the cause of the problem, a minimum of 1 hour labour at £30 per hour plus carriage costs will be required before the equipment will be despatched back to the customer.

Any equipment repaired or replaced under warranty will normally be ready for shipment back to the customer within 7 working days upon receipt of the equipment at an authorised Jefferson Repair centre (subject to part availability). Where parts are not immediately available Jefferson will contact you with a revised date for completion of the repair.

General Warranty Enquiries

For any further information relating to Jefferson warranty cover please call **+44 (0) 1244 646 048** or send your enquiry via email to **warranty@jeffersontools.com**



Disclaimer:

The information in this document is to the best of our knowledge true and accurate, but all recommendations or suggestions are made without guarantee. Since the conditions of use are beyond their control, Jefferson Tools® disclaim any liability for loss or damage suffered from the use of this data or suggestions. Furthermore, no liability is accepted if use of any product in accordance with this data or suggestions infringes any patent. Jefferson Tools® reserve the right to change product specifications and warranty statements without further notification. All images are for illustration purposes only.



EC Declaration of Conformity

We, Jefferson Professional Tools & Equipment, as the authorised European

Community representative of the manufacturer, declare that the following equipment

conforms to the requirements of the following Directives:

2000/14/EC (as amended) Noise Emission in the Environment by Equipment

for Use Outdoors

2004/108/EC (as amended) Electromagnetic Compatibility

2006/42/EC (as amended) Machinery Directive

97/68/EC (as amended) Non Road Mobile Machinery Directive

Equipment Category: Power Generator (Item 45)

Product Name/Model: JEFGENPET63EL (GG7150E) 7.9kVA / 6.3kW Petrol Generator

Rated Power: 7.2kVA / 5.8kW

The conformity assessment procedure followed was in accordance with Annex VI of the Outdoor Noise Directive

Notified Body: SNCH Luxembourg GmbH. (No. 0499)

Measured Sound Power Level: 97dB

Guaranteed Sound Power Level: 97dB

A copy of this certificate has been submitted to the European Commission and to the

EU Member State, United Kingdom

Signed by: Stephen McIntyre

Position in the company: Operations Director

Date: 29 September 2014

This technical document is held by: Jimmy Hemphill

Technical file holder's address as shown below

Name and address of manufacturer or authorised representative:

Jefferson Tools, Herons Way, Chester Business Park, Chester, United Kingdom, CH4 9QR **Telephone:** +44 (0)1244 646 048 **Fax:** +44 (0)1244 241 191 **Email:** enquiries@jeffersontools.com **www.jeffersontools.com**





14. Notes

IMPORTANT! SAFETY FIRST!

Before attempting to use this product please read all the safety precautions and operating instructions outlined in this manual to reduce the risk of fire, electric shock or personal injury.

Jefferson Tools, Herons Way, Chester Business Park, Chester, United Kingdom, CH4 9QR

Tel. +44 (0)1244 646 048 Email: sales@jeffersontools.com

www.jeffersontools.com